



Washington County

M A R Y L A N D

DIVISION OF ENGINEERING

**ADDENDUM NO. 1**

TO: Interested Parties

FROM: Pam Mohn, P.E.  
Chief of Design, Engineering

DATE: Thursday, August 15, 2019

RE: Holiday Drive Curb  
Request for Quotes

---

Acknowledge receipt of this **Addendum No. 1** by signing in the space provided below and returning with your Bid.

Failure to sign and return with your Bid may subject the Bidder to disqualification. This **Addendum No. 1** forms a part of the Bid Documents, it supplements and modifies them as outlined herein.

This **Addendum No. 1** consists of  3  pages, including this page and attachments.

I hereby acknowledge receipt of **Addendum No. 1**:

By: \_\_\_\_\_ Date \_\_\_\_\_  
Signed Name

\_\_\_\_\_  
Typed Name

\_\_\_\_\_  
Title

For: \_\_\_\_\_

80 West Baltimore Street | Hagerstown, MD 21740-6003 | P: 240.313.2460 | TDD: 711

WWW.WASHCO-MD.NET


**Holiday Drive Curb**

**Request for Quotes**

Date Issued: **Thursday, August 15, 2019**

Bids Due: **Friday, August 16, 2019**  
**2:00 p.m., E.S.T.**


The following addendum material is hereby made a part of the Bid Documents. Please note the following changes, information, and/or instructions in connection with the proposed work and submit proposals accordingly.



---

Mark Mishler  
Civil Engineer, Engineering

By Authority of:  
Board of County Commissioners  
Washington County, Maryland



---

Pam Mohn, P.E.  
Chief of Design, Engineering

## ADDENDUM NO. 1

### Holiday Drive Curb

### Request for Quotes

**TO:** All prime potential bidders.

**ITEM 1.01** **PRE-QUOTATION MEETING MINUTES:** No pre-quotation meeting was held for this project. The Addendum consists of three (3) total pages, all of which shall be incorporated into the Contract Document.

#### **ITEM 1.02** Questions

**Q1:** In the summary it specs a 24" high curb and a 12" wide gutter, but the diagram does not show gutter. Is a concrete gutter required for the project?

**R1:** **No. The new concrete curb shall be a 24-inch high curb and no gutter pan.**

**Q2:** Can the Contractor saw cut the asphalt in a straight line and pour the curb against it?

**R2:** **Yes. The concrete curb can be poured against the asphalt assuming it remains in acceptable condition following the saw cut.**

**END ADDENDUM NO. 1**