



**ADDENDUM NO. 2**

TO: Interested Parties

FROM: Brennan Garrett, Senior Architectural Project Manager  
Division of Engineering

DATE: Friday, June 4, 2021

PROJECT: 17718 VIRGINIA AVENUE HVAC REPLACEMENT (PHASE-2)  
COUNTY CONTRACT NO. MS-HV-291-28

---

Acknowledge receipt of this **Addendum No. 2** by signing in the space provided below and returning with your Bid.

Failure to sign and return with your Bid may subject the Bidder to disqualification. This **Addendum No. 2** forms a part of the Bid Documents, it supplements and modifies them as outlined herein.

This **Addendum No. 2** consists of **3 pages**, including this page.

I hereby acknowledge receipt of **Addendum No. 2**:

By: \_\_\_\_\_ Date \_\_\_\_\_  
Signed Name

\_\_\_\_\_  
Typed Name

\_\_\_\_\_  
Title

For (Firm): \_\_\_\_\_

Phone Number: \_\_\_\_\_

**ADDENDUM NO. 2**  
**Page 1 of 3**

**ADDENDUM NO. 2**

**17718 VIRGINIA AVENUE HVAC REPLACEMENT (PHASE-2)**


**Washington County Contract No. MS-HV-291-28**

Date Issued: Friday, June 4, 2021

Bids Due: **Wednesday, June 9, 2021**  
**2:00 p.m., Local Time**


The following addendum material is hereby made a part of the Bid Documents.

Please note the following changes, information, and/or instructions in connection with the proposed work and submit proposals accordingly.



Brennan Garrett  
Senior Architectural Project Manager  
Division of Engineering

By Authority of:  
Board of County Commissioners  
Washington County, Maryland



Scott Hobbs, P.E.  
Director  
Division of Engineering

**ADDENDUM NO. 2**

**17718 VIRGINIA AVENUE HVAC REPLACEMENT (PHASE-2)**

**Washington County Contract No. MS-HV-291-28**

TO: All prime Contractors and all others to whom specifications have been issued.

**ITEM 1.01    CHANGES/REVISIONS:**

**Incorporate the following into the Bid Document:**

**ADD:**

**Add the following:** Roof top unit Nos. 1, 3, 4 and 5 shall include a powered convenience outlet and disconnect.

***END OF ADDENDUM NO. 2***