



ADDENDUM NO. 2

TO: Interested Parties

FROM: Jessica Spring, Project Manager
Division of Engineering

DATE: Tuesday, April 20, 2021

PROJECT: 33/35 WEST WASHINGTON STREET
COMMUNICATION TOWER EXTENSION
COUNTY CONTRACT NO.: MS-CT-083-18

Acknowledge receipt of this **Addendum No. 2** by signing in the space provided below and returning with your Bid.

Failure to sign and return with your Bid may subject the Bidder to disqualification. This **Addendum No. 2** forms a part of the Bid Documents, it supplements and modifies them as outlined herein.

This **Addendum No. 2** consists of **eight (8) pages**, including this page.

I hereby acknowledge receipt of **Addendum No. 2**:

By: _____ Date _____
Signed Name

Typed Name

Title

For (Firm): _____

Phone Number: _____

ADDENDUM NO. 2
Page 1 of 8

ADDENDUM NO. 2

**33/35 WEST WASHINGTON STREET
COMMUNICATION TOWER EXTENSION**


COUNTY CONTRACT NO. MS-CT-083-18

Date Issued: Tuesday, April 20, 2021

**Bids Due: REVISED: Friday, April 23, 2021
2:00 p.m., Local Time**


The following addendum material is hereby made a part of the Bid Documents.

Please note the following changes, information, and/or instructions in connection with the proposed work and submit proposals accordingly.



Jessica Spring, Project Manager
Division of Engineering

By Authority of:
Board of County Commissioners
Washington County, Maryland



Scott Hobbs, P.E., Director
Division of Engineering

ADDENDUM NO. 2

33/35 WEST WASHINGTON STREET COMMUNICATION TOWER EXTENSION

COUNTY CONTRACT NO. MS-CT-083-18

TO: All prime Contractors and all others to whom specifications have been issued:

ITEM 2.01 **REVISED BID DUE DATE**

The date for acceptance of bids is changed as follows:

The Board of County Commissioners of Washington County, Maryland, will accept sealed bids for the 33/35 West Washington Street, Communication Tower Extension, Contract No. MS-CT-083-18 until Friday, April 23, 2021 at 2:00 p.m.

ITEM 2.02 **PRE-BID QUESTIONS & RESPONSES:**

The question period ended at 4:00 p.m. on Friday, April 9, 2021. Additional questions received include the following:

Q1: We have a couple of questions regarding the material. Are you providing the tower, coax and new antennas or do we have to figure that into our cost? The SOW doesn't really say.

R1: **The existing communication tower is a 45g steel tower. The materials necessary to extend the tower, including but not limited to steel, brackets, and anchoring materials, shall be furnished and installed by the contractor.**

The feedlines for all existing antennas identified for relocation may be spliced with back-to-back connectors in order to extend the coax. All materials required for coax feedline extension shall be furnished and installed by the contractor.

All new coax feedlines required for added antennas shall be furnished and installed by the contractor. The new feedlines shall extend to the 4th floor server room located on the top floor of the building. Access to the server room is available through an existing *Qwikport* located on the rooftop.

The bid document identifies three (3) new antennas and associated mounts to be added to the tower. The two (2) new Diamond antennas will be furnished by the County. Contractor shall furnish mounting hardware. The Telewave ANT150D6-9 antenna is currently on the rooftop and attached to the side of elevator shaft. The contractor shall relocate this existing antenna onto the tower as noted in the Bid Document.

All antenna identified by the Bid Document for removal shall be salvaged and returned to the County.

Q2: Is this building active?

R2: **Yes, the building is active and occupied during the work week, Monday through Friday, 7:30 a.m. – 4:30 p.m. Refer also to Addendum No. 1, Item 1.03, Access and Safety. Additionally, all antenna identified by this project for relocation are currently**

ADDENDUM NO. 2

**33/35 WEST WASHINGTON STREET
COMMUNICATION TOWER EXTENSION**

COUNTY CONTRACT NO. MS-CT-083-18

active and in service. Any disruption to service as a result of antenna relocation shall be kept to one working day.

END OF ADDENDUM NO. 2

Attachments: Photographs (4 pages)

33/35 West Washington Street Communication Tower Extension
Addendum No. 2 Photographs



Fourth Floor Server Room Qwikport Access

**33/35 West Washington Street Communication Tower Extension
Addendum No. 2 Photographs**



Qwikport Access on rooftop

**33/35 West Washington Street Communication Tower Extension
Addendum No. 2 Photographs**



Looking through Qwikport Access to Fourth Floor Server Room

**33/35 West Washington Street Communication Tower Extension
Addendum No. 2 Photographs**



Elevator Shaft Antenna