



PURCHASING DEPARTMENT  
DIVISION OF BUDGET & FINANCE

**PUR-1513  
ADDENDUM NO. 4  
INVITATION TO BID**

**FORT RITCHIE GRAVITY LINES AND MANHOLE REPLACEMENT**

DATE: Tuesday, January 18, 2022

**BIDS DUE: Friday, January 21, 2022**

*(Revised Date via – Addendum No. 4) 2:00 P.M. (EDT/EST)*

To Bidders:

This Addendum is hereby made a part of the Contract Documents on which all bids will be based and is issued to correct and clarify the original documents.

Please acknowledge receipt of this Addendum at the appropriate space on the Proposal Form. This Addendum consists of one (1) page.

**NOTE: Washington County Government has limited access to the Washington County Administration Complex at 100 West Washington Street, Hagerstown, Maryland until further notice. All Bidders shall allow ample time for delivery of their bid packets. Delivery of bid packets via-courier service or United States Postal Service (USPS) will be accepted. Those bidders who wish to deliver their bid packet in-person will need to call 240-313-2330 to receive instructions for submitting their bid packet.**

**ITEM NO. 1:** All references in the bid document made to the Bid Opening Time / Location shall be changed to read: No later than **2:00 P.M., (EDT/EST), Friday, January 21, 2022**, Washington County Administration Complex.

**ITEM NO. 2:** Due to the Coronavirus (COVID-19) pandemic Washington County Purchasing has canceled all face-to-face meetings. All interested parties are invited to hear a reading of the bids. For those bidders who wish to hear a reading of the bids shall call 240-313-2330 to receive instructions for a reading of the bids.

**ITEM NO. 3:** Inquiry: With the sewer line still being active will a pump around be required.

Response: Yes, the sewer line is active so a pump around is required.

By Authority of:

Rick F. Curry, CPPO  
Director of Purchasing

100 West Washington Street, Room 3200 | Hagerstown, MD 21740-4748 | P: 240.313.2330 | F: 240.313.2331 | TDD: 711