



**2025 WATER QUALITY REPORT FOR  
THE ELK RIDGE WATER SYSTEM  
PWSID # 0210006**

**Is my water safe?**

Last year, as in years past, your tap water met all U.S. Environmental Protection Agency (EPA) and state drinking water health standards. The Washington County Department of Water Quality vigilantly safeguards its water supplies.

**Do I need to take special precautions?**

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised people such as people with cancer undergoing chemotherapy, people who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on proper means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Water Drinking Hotline (1-800-426-4791).

**Where does my water come from?**

The Elk Ridge Water System utilizes one well as its water source. The water for this system receives iron removal, manganese removal, pH adjustment and chlorination prior to entering the distribution system.

**Source water assessment and its availability**

The Maryland Department of the Environment's Water Supply Program (WSP) has conducted a Source Water Assessment for the Elk Ridge water system. The required components of this report as described in Maryland's Source Water Assessment Program (SWAP) are 1) delineation of an area that contributes water to the source, 2) identification of potential sources of contamination, and 3) determination of susceptibility of the water supply to contamination. Recommendations for protecting the drinking water supply are included in this report.

The source of Elk Ridge's water supply is one well in an unconfined fractured rock aquifer. The Source Water Assessment area was delineated by the WSP using EPA approved methods specifically designed for this source type. Point sources of contamination were investigated within the assessment area from field inspections, contaminant inventory databases, and previous studies. The Maryland Office of Planning's 2000 digital land use map for Washington County was used to identify non-point sources of contamination. Well information and water quality data were also reviewed.

The susceptibility analysis is based on review of the existing water quality data for the Elk Ridge Water System, the presence of potential sources of contamination in the source water assessment area, well integrity, and the inherent vulnerability of the aquifer. The Elk Ridge Water supply may be susceptible to contamination by volatile organic compounds. It was determined that Radon-222, a naturally occurring contaminant, may pose a risk to the Elk Ridge water supply.

**Why are there contaminants in my drinking water?**

Drinking water, including bottled water, may reasonably be expected to contain at least some small amounts of contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More

information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it can dissolve naturally occurring minerals and radioactive materials and pick up substances resulting from the presence of animals or human activity.

Possible contaminants consist of:

**Microbial contaminants**, such as viruses and bacteria, may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife

**Inorganic contaminants**, such as salts and metals, may be naturally occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming

**Pesticides and herbicides** may come from a variety of sources such as agriculture, urban stormwater runoff and residential uses

**Organic chemical contaminants**, including synthetic and volatile organic chemicals, are by-products of industrial processes and petroleum production, and may also come from gas stations, urban stormwater runoff and septic systems

**Radioactive contaminants** may be naturally occurring or be the result of oil and gas production and mining activities

### **How can I get involved?**

For more information on getting involved, please contact Washington County Department of Water Quality at (240) 313-2600.

### **Water Quality Data Table**

To ensure that tap water is safe to drink, EPA prescribes regulations which limit the number of contaminants in water provided by public water systems. The table below lists all the drinking water contaminants that we detected during the calendar year of this report.

Although many more contaminants were evaluated, only those substances listed below were found in your water. All sources of drinking water have some naturally occurring contaminants. At low levels, these substances are generally not harmful in our drinking water. Removing all contaminants would be extremely expensive, and in most cases, would not supply increased protection of public health.

A few naturally occurring minerals may improve the taste of drinking water and have nutritional value at low levels. Unless otherwise noted, the data presented in this table is from testing done in the calendar year of the report. The EPA or the State requires us to monitor certain contaminants less than once per year because the concentration of these contaminants does not vary significantly from year to year, or the system is not considered vulnerable to this type of contamination. As such, some of our data, though representative, may be more than one year old. In this table you will find terms and abbreviations that might not be familiar to you. To help you better understand these terms, we have supplied the definitions at the end of this document

Disinfectants & Disinfectant By-Products								
Contaminant	MCLG or MRDLG	MCL, TT, or MRDL	Your Water	Range		Sample Date	Units	Typical Source
				Low	High			
Chlorine	4	4	1.45	0.2	2.7	2025	ppm	Water additive used to control microbes
Total Trihalomethanes (TTHM)	No goal for the total	80	<0.5			9/11/2024	ppb	By-product of drinking water disinfection
Haloacetic Acids (HAA5)	No goal for the total	60	<1			9/11/2024	ppb	By-product of drinking water disinfection
There is convincing evidence that the addition of disinfectant is necessary for control of microbial contaminants. Not all sample results may have been used for calculation the Highest Level Detected because some results may be part of an evaluation to determine where compliance sampling should occur in the future.								
Inorganic Contaminants								
Contaminant	MCLG or MRDLG	MCL, TT, or MRDL	Your Water	Range		Sample Date	Units	Typical Source
				Low	High			
Nitrate (measured as Nitrogen)	10	10	<0.25	<0.25	<0.25	6/19/2025	ppm	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Barium	2	2	<0.1	<0.1	<0.1	5/10/2023	ppm	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
Chromium	100	100	2	0	2	5/10/2023	ppb	Discharge from steel and pulp mills Erosion of natural deposits
Fluoride	4	4	0.1	0	0.1	5/10/2023	ppm	Erosion of natural deposits; Water additive which promotes strong teeth; Dishcharge from fertilizer and aluminum factories
Organic Contaminants								
Contaminant	MCLG or MRDLG	MCL, TT, or MRDL	Your Water	Sample Date		Units	Typical Source	
Toluene	1	1	0.0163	10/11/2023		ppm	Discharge from petroleum factories.	
Radiological Contaminants								
Contaminant	MCLG or MRDLG	MCL, TT, or MRDL	Your Water	Sample Date		Units	Typical Source	
Gross Alpha, Exc Radon	0	15	3.1	8/24/2021		pCi/L	Erosion of natural deposits	
Radium-228	0	5	0.5	8/24/2021		pCi/L	Erosion of natural deposits	
Lead and Copper								
Contaminant	Sample Date	Action Level (AL)	90th Percentile	# of Sites over AL	Units	Range		Typical Source
						Low	High	
Copper	6/13/2025	1.3	0.192	0	ppm	<0.05	0.219	Corrosion of household plumbing systems; Erosion of natural deposits; leaching from wood preservatives
Lead	6/13/2025	15	1.7	0	ppb	<2	3.3	Corrosion of household plumbing systems; Erosion of natural deposits

Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Washington County is responsible for providing high quality drinking water and removing lead pipes but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's

risk. Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standards Institute accredited certifier to reduce lead in drinking water. If you are concerned about lead in your water and wish to have your water tested, contact Washington County at 240-313-2600. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <http://www.epa.gov/safewater/lead>.

An initial inventory of service line pipe materials located within our service area was required to be submitted to the Maryland Department of the Environment (MDE) by October 16, 2024. Our initial survey was submitted to MDE on 10/14/2024 and is available upon request. The inventory survey is still ongoing and will be updated annually. To assist in the survey or for help identifying your service line material please scan the QR code below or call 240-313-2600 for assistance.



**PFAS Statement**

PFAS – short for per- and polyfluoroalkyl substances – refers to a large group of more than 4,000 human-made chemicals that have been used since the 1940s in a range of products, including stain- and water-resistant fabrics and carpeting, cleaning products, paints, cookware, food packaging and fire-fighting foams. These uses of PFAS have led to PFAS entering our environment, where they have been measured by several states in soil, surface water, groundwater, and seafood. Some PFAS can last a long time in the environment and in the human body and can accumulate in the food chain.

The Environmental Protection Agency (EPA) announced regulations for 6 PFAS compounds in drinking water in April 2024. The MCLs for PFOA and PFOS are each 4.0 parts per trillion (ppt). The MCLs for PFNA, PFHxS, and HFPO-DA (GenX chemicals) are each 10 ppt. Additionally, a mixture of two or more of the following chemicals (PFNA, PFHxS, HFPO-DA, and PFBS) use a Hazard Index of 1 (unitless) to determine if the combined levels of these PFAS pose a risk and require action. Public water systems have three years (by 2029) to implement solutions that reduce these PFAS if monitoring shows that drinking water levels exceed these MCLs.

The Maryland Department of the Environment (MDE) conducted a PFAS monitoring program for Community Water Systems from 2020 to 2022. The results are available on MDE’s website:

[https://marylanddepartmentoftheenvironment.shinyapps.io/MDE\\_PFAS\\_PublicWaterSystemStudyMap/](https://marylanddepartmentoftheenvironment.shinyapps.io/MDE_PFAS_PublicWaterSystemStudyMap/)

Your water analyses results for 2022 are in the table below:

Unregulated Contaminants - PFAS		
Analyte	Your Water	Units
PFOA	1.43	ppt
PFOS	2.26	ppt
PFBS	7.55	ppt
PFNA	<1.5	ppt
PFHxS	2.63	ppt
HFPO-DA	<1.0	ppt

## **Voluntary Monitoring**

The Washington County Department of Water Quality conducts routine testing of your water system that is not included in the Water Quality Data Table. MDE has also completed testing that is not included in the Water Quality Data Table. A list of these parameters and their results are in the Table of Results of Customer Interest below.

<b>PARAMETERS</b>	<b>LEVEL/RANGE DETECTED</b>	<b>UNIT OF MEASUREMENT</b>
pH	6.6-7.8	Standard Unit
Turbidity	0.1-0.9	NTU
Hardness	86-154	ppm
Alkalinity	84-111	ppm
Manganese	0.00-0.08	ppm

## **Important Terms**

<b>Unit / Term Descriptions</b>	
<b>Unit / Term</b>	<b>Definition</b>
<b>ppm</b>	ppm: parts per million, or milligrams per liter (mg/L) or one ounce in 7,350 gallons of water
<b>ppb</b>	ppb: parts per billion, or micrograms per liter (µg/L) or one ounce in 7,350,000 gallons of water.
<b>ppt</b>	ppt; part per trillion or one ounce in 73,500,000 gallons of water
<b>pCi/L</b>	pCi/L: picocuries per liter (a measure of radioactivity)
<b>NA</b>	NA: Not applicable
<b>ND</b>	ND: Not detected
<b>NR</b>	NR: Monitoring not required but recommended
<b>MCLG</b>	MCLG: Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety
<b>MCL</b>	MCL: Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology
<b>AVG</b>	Compliance with some MCL's is based on running average of monthly samples
<b>TT</b>	Technique: A required process intended to reduce the level of contaminants in drinking water
<b>AL</b>	AL: Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow
<b>Variations and Exemptions</b>	Variations and Exemptions: State or EPA permission not to meet an MCL or a treatment technique under certain conditions
<b>MRDLG</b>	MRDLG: Maximum residual disinfection level goal. The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants
<b>MRDL</b>	MRDL: Maximum residual disinfectant level. The highest level of a disinfectant allowed in drinking water. There is convincing evidence that the addition of a disinfectant is necessary for control of microbial contaminant.
<b>MNR</b>	MNR: Monitored Not Regulated
<b>MPL</b>	MPL: State Assigned Maximum Permissible Level

**For more information on the  
Elk Ridge Water System contact  
the Washington County  
Department of Water Quality  
at 240-313-2600**