

## Sandy Hook WwTP Ultraviolet Disinfection System Replacement

				Chesapeake Environmental Equipment Midlothian, VA	UVSYSCO LLC Nanuet, NY
Item No.	Item Description	Unit of Measure	Qty.	Total Price	Total Price
1	Removal of existing UV system and furnish and install new UV system	Each	1	\$22,500.00	\$19,500.00

*\*Corrected calculations based on unit pricing*

**Remarks/Exceptions:**

**Chesapeake Environmental Equipment** - Delivery/Service can be performed no later than **90** calendar days from receipt of order. The enclosed Glasco proposal has "startup" included in the price. This start-up consists of installing unit into channel & performing training & working with on site electrician to make sure power connections are secure. There are no channel modifications needed for it is a "like for like" replacement. We only need flow diverted & on-site MD electrician. We do not dispose of any equipment or act as a general contractor. The estimated time to perform the installation is 4 - 6 hours. This is a straight forward installation & historically have been done with little interruptions. This project will be no different.

**UVSYSCO LLC** - Non-Responsive due to not submitting a substitution request for the proposed product. Addendum No. 2 not acknowledged. Delivery/Service can be performed no later than **90** calendar days from receipt of order. The equipment being supplied by UVSYSCO is done under contract with Donnellan UV, owner of the Sunlight Siemens biologically validated product line. Systems were previously marketed through another company, but as of January 2021 they entered into agreement with UVSYSCO to provide this ETV validated equipment.